



EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB 5. Kısım Fırat Caddesi No:18
41455 Dilovası KOCAELİ
www.effectis.com

TEST CERTIFICATE

Certificate Nr: EEA – 1800 – 0017

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on 30.01.2018 in accordance with EN 1366-2:2015 standard for the product as described below:

“ FEN ” FIRE DAMPER

FIRE RESISTANCE CLASSIFICATION

EI 180 (ve, i→o) S

Placed on the market by

KES KLİMA SAN. ve TİC. LTD. ŞTİ.

İvedik Org. San. Bölğ. 1420. Cad. No:58 Yenimahalle/ ANKARA / TURKEY

And Produced In the Factory

KES KLİMA SAN. ve TİC. LTD. ŞTİ.

İvedik Org. San. Bölğ. 1420. Cad. No:58 Yenimahalle/ ANKARA / TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **EEA – 18– 005**.

This certificate is initially valid until 31st January 2019 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
31.01.2018





EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB 5. Kısım Fırat Caddesi No:18
41455 Dilovası KOCAELİ
www.effectis.com

TEST CERTIFICATE

Certificate Nr: EEA – 1800 – 0018

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on 30.01.2018 in accordance with EN 1366-2:2015 standard for the product as described below:

“ FEN ” FIRE DAMPER

FIRE RESISTANCE CLASSIFICATION

EI 240 (ve, o→i) S

Placed on the market by

KES KLİMA SAN. ve TİC. LTD. ŞTİ.

İvedik Org. San. Bölğ. 1420. Cad. No:58 Yenimahalle/ ANKARA / TURKEY

And Produced In the Factory

KES KLİMA SAN. ve TİC. LTD. ŞTİ.

İvedik Org. San. Bölğ. 1420. Cad. No:58 Yenimahalle/ ANKARA / TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **EEA – 18– 005**.

This certificate is initially valid until 31st January 2019 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
31.01.2018





EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB 5. Kısım Fırat Caddesi No:18
41455 Dilovası KOCAELİ
www.effectis.com

TEST CERTIFICATE

Certificate Nr: EEA – 1800 – 0019

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on 14.02.2018 in accordance with EN 1366-2:2015 standard for the product as described below:

“ FEN ” FIRE DAMPER

FIRE RESISTANCE CLASSIFICATION

EI 180 (ho, i→o) S

Placed on the market by

KES KLİMA SAN. ve TİC. LTD. ŞTİ.

İvedik Org. San. Böl. 1420. Cad. No:58 Yenimahalle/ ANKARA / TURKEY

And Produced In the Factory

KES KLİMA SAN. ve TİC. LTD. ŞTİ.

İvedik Org. San. Böl. 1420. Cad. No:58 Yenimahalle/ ANKARA / TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **EEA – 18– 006**.

This certificate is initially valid until 15th February 2019 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
15.02.2018





EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB 5. Kısım Fırat Caddesi No:18
41455 Dilovası KOCAELİ
www.effectis.com

TEST CERTIFICATE

Certificate Nr: EEA – 1800 – 0020

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on 14.02.2018 in accordance with EN 1366-2:2015 standard for the product as described below:

“ FEN ” FIRE DAMPER

FIRE RESISTANCE CLASSIFICATION

EI 180 (ho, o→i) S

Placed on the market by

KES KLİMA SAN. ve TİC. LTD. ŞTİ.

İvedik Org. San. Bölğ. 1420. Cad. No:58 Yenimahalle/ ANKARA / TURKEY

And Produced In the Factory

KES KLİMA SAN. ve TİC. LTD. ŞTİ.

İvedik Org. San. Bölğ. 1420. Cad. No:58 Yenimahalle/ ANKARA / TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **EEA – 18– 006**.

This certificate is initially valid until 15th February 2019 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
15.02.2018

