



EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB 5. Kısım Fırat Caddesi No:18
41455 Dilovası KOCAELİ
www.effectis.com

TEST CERTIFICATE

Certificate No: EEA – 1800 – 0103

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on **21.12.2018** in accordance with EN 1366-2:2015 standard for the product as described below:

“ FEN 30.AA.00 – 1000 x 650 ” FIRE DAMPER

With fusible link

FIRE RESISTANCE CLASSIFICATION

EI 120 (ve, i↔o) S

Placed on the market by

KES KLİMA SAN. ve TİC. LTD. ŞTİ.

Saray Mah. Saraykent San. Böl. 60.Cadde No:33 Kahramankazan, ANKARA/TURKEY

And produced in the factory

KES KLİMA SAN. ve TİC. LTD. ŞTİ.

Saray Mah. Saraykent San. Böl. 60.Cadde No:33 Kahramankazan, ANKARA/TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **EEA – 18 – 146**.

This certificate is initially valid until **25th December 2019** providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
24.12.2018

